

## Low Voltage Programmable Thermostat Test Results

<b>Participant Name:</b> White-Rodgers	<b>Manufacturer Name:</b> White-Rodgers
<b>Model No:</b> 1F95-1277, 1F97-1277	<b>Sample No:</b> 1F95-1291
<b>Testing Laboratory:</b>	<b>Test Report Date:</b> May 12th, 2014
<b>Signed by:</b> Jagdish Atri	<b>Title:</b> Manager- Electrical Products

Annex A Clause number	Feature	Criteria	Test method	Test Result
A.2.1	Programming	5-2, 5-1-1, or 7-day	Visual inspection	5-2,5-1-1,or 7day
A.2.2	Programming events	At least 4	Visual inspection	Yes
A.2.2	Setback interval	Min 8 hours	Visual inspection	Yes
A.3	Backlight	Yes/No	Visual inspection	Yes
A.4	Default schedule	Table 1/Table2 & 3	Visual inspection	Yes
A.4	Restore default schedule	Yes/No	Visual inspection	Yes
A.7	Recovery type	Conventional/adaptive	Visual inspection	Yes
A.8	Temporary hold	Yes/No	Visual inspection	Yes
A.9	Permanent hold	Yes/No	Visual inspection	Yes
A.10	Battery back-up or non-volatile memory	Yes/No	Visual inspection	Yes
A13.1	Operating differential - Heating	within 2°F (1.1°C)	Test chamber	Yes
A13.2	Operating differential - Cooling	within 2°F (1.1°C)	Test chamber	Yes
A13.3	Droop	maximum of 1.5°F (0.8°C)	Test chamber	Yes
A.14	Static temperature accuracy	±1.0° F (0.6°C)	Test chamber	Yes
A.15.1	Auxiliary heat indicator	Yes/No	Visual inspection	Yes
A.15.2	Hold indicator	Yes/No	Visual inspection	Yes
A.15.3	Battery indicator (if battery is used)	Yes/No	Visual inspection	Yes